

Greenheck Fan Recalls Indirect Gas Fired Furnaces Due to Risk of Fire

Toronto, ON – The Electrical Safety Authority in cooperation with Greenheck Fan Corp. is notifying the public that Greenheck Fan Corp. has announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately.

Name of Product: Indirect Gas-Fired Furnaces.

Units: 94 units in Canada (37 units in Ontario).

Manufacturer/Importer: Greenheck Fan Corp., of Schofield, Wis.

Hazard: The ignition control module can fail preventing the unit from shutting down in high temperature conditions. This poses a risk of fire, as well as hazardous fumes being released from burning/melting insulation.

Incidents/Injuries: No incidents or injuries have been reported.

Description/Models: The recall involves Greenheck Fan Indirect Gas-Fired Furnaces models PVF, PVFH, IGX, IG, ERH and ERCH. The model name is located on the control center door or the furnace door. The furnace is either natural gas or LP gas (propane) fueled. Only units with ignition control module model number 35-615922-125 are included in the recall.

Sold through: Greenheck sales representatives to mechanical contractors nationwide from November 2006 through October 2007 for between \$2,000 and \$100,000.

Manufactured in: United States

Remedy: Property managers or job sites who have not been contacted by Greenheck Fan should contact the firm to arrange for a free repair.

Consumer Contact: For additional information, contact Greenheck Fan at (800) 931-6579 between 8:00 a.m. and 5:00 p.m. CT Monday through Friday anytime, or visit the firm's Web site at www.greenheck.com

